

16.05.050 Earthquake shutoff valve required.

All new gas services and existing services that are expanded shall have an approved earthquake shutoff valve installed in the building supply line immediately after the gas meter. The valve shall be located outside of the structure and be readily accessible.

(Ord. O2010-283 § 1 (Att. A); Ord. O2004-148 § 2)