



## ***Fire Prevention Bureau Plan Review***

**Date:** March 30, 2017

**From:** Jeff Werre, Assistant Fire Marshal

**Re:** Permit number: SSDP2017-00414

Project name: King County Inglewood Hill Parking Lot

Plans dated: 10/21/16

Listed below are comments/conditions regarding our plan review for the permit number which is noted above. If you have any questions regarding these comments please feel free to call (425) 313-3324.

Please submit for re-review when these items below have been addressed.

- Fire lanes shall be striped or signs installed at entrance and exit. Please submit fire lane plan to Eastside Fire & Rescue for review. If using signs please provide a sign detail of the "No Parking Fire Lane" for review.